

December, 2019
B.Tech - 5th Sem
Refrigeration and Air Conditioning (ME-303-C)

Duration: 3 Hours

Max. Marks: 75

Instructions:

- It is compulsory to answer all the questions (1.5 marks each) of Part-A in short.
- Answer any four questions from Part-B in detail.
- Different sub-parts of a question are to be attempted adjacent to each other.

PART A

- Q1**
- (a) What are the desirable properties of an ideal refrigerant? (1.5)
 - (b) Explain the term “tonne of refrigeration”. (1.5)
 - (c) What is the effect of degree of superheating and degree of subcooling on COP of vapour compression refrigeration system? (1.5)
 - (d) What are the advantages of multistage compression with intercooler over single stage compression? (1.5)
 - (e) How the function of compressor is achieved in vapour absorption refrigeration system (1.5)
 - (f) Define the term dew point temperature and degree of saturation. (1.5)
 - (g) Show the process of cooling and dehumidification on psychrometric chart. (1.5)
 - (h) What are the different factors to be considered in load estimation sheet for comfort application. (1.5)
 - (i) Write the classification of duct. (1.5)
 - (j) On what factors does the volumetric efficiency of a compressor depend? (1.5)

PART B

- Q2**
- (a) Explain the working of a bell-Coleman cycle and derive its COP. Also show the various processes on P-V and T-S diagram (8)
 - (b) Explain, with a neat sketch, the working of a simple air evaporative cooling system. (7)

- Q3** (a) An ammonia refrigerating machine fitted with an expansion valve works between the temperature limits of -10°C and 30°C . The vapour is 95% dry at the end of isentropic compression and the fluid leaving the condenser is at 30°C . Assuming actual COP as 60% of the theoretical, calculate the kilograms of ice produced per kW hour at 0°C from water at 10°C . Latent heat of ice is 335 kJ/kg. (15)

Temperature $^{\circ}\text{C}$	Liquid heat (h_l) kJ/kg	Latent heat (h_{fg}) kJ/kg	Liquid entropy (s_f) kJ/kg K
30	323.08	1145.8	1.2037
-10	135.37	1297.68	0.5443

- Q4** Explain with the help of a neat sketch, the working of a refrigerating system having three evaporators at different temperatures with individual compressors and multi expansion valves. (15)
- Q5** (a) Draw a neat diagram of lithium bromide water absorption system and explain its working. List the major field of applications of this system (8)
(b) Explain with a neat sketch, the working of a steam jet refrigeration system (7)
- Q6** A conference room for seating 100 persons is to be maintained at 22°C dry bulb temperature and 60% relative humidity. The outdoor conditions are 40°C dry bulb temperature and 27°C wet bulb temperature. The various loads in the auditorium are as follows: Sensible and latent heat loads per person, 80 W and 50 W respectively; lights and fans, 15 kW; sensible heat gain through glass, walls, ceiling etc., 15kW. The air infiltration is $20\text{m}^3/\text{min}$ and fresh air supply is $100\text{m}^3/\text{min}$. Two-third of recirculated room air and one third of fresh air is mixed before entering the cooling coil. The by-pass factor of the coil is 0.1. Determine apparatus dew point, the grand total heat load and effective room sensible heat factor. (15)
- Q7** Write short notes on: (i) Thermodynamic Wet Bulb temperature (ii) Summer air conditioning system (iii) Different types of compressor used in refrigeration (15)



pyqfort.com

Praxian